

EU-TYPE EXAMINATION CERTIFICATE



Component intended for use on/in Equipment or Protective System Intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU

EU-Type Examination Certificate Number: **DEMKO 15 ATEX 1575U Rev. 3**

Component: **Flameproof Operators**

Manufacturer: **Adalet/Scott Fetzer Co.**

Address: **4801 W. 150th Street, Cleveland, OH 44135 USA**

This product and any acceptable variation thereto are specified in the schedule to this certificate and the documents therein referred to.

UL International Demko A/S, notified body number 0539 in accordance with Article 17 of the Council Directive 2014/34/EU of the European Parliament and the Council, dated 26 February 2014, certifies that this component has been found to comply with the Essential Health and Safety Requirements relating to design and construction of components intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential report no. **US/UL/ExTR15.0144/03**.

Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN IEC 60079-0:2018

EN 60079-1: 2014

The sign "U" is placed after the certificate number. It indicates that this certificate must not be mistaken for a certificate intended for an equipment or protective system. This partial certification may be used as a basis for certification of an equipment or protective system.

This EU-Type Examination Certificate relates only to the design and construction of the specified component. Further requirements of the Directive apply to the manufacturing process and supply of this component. These are not covered by this certificate.

The marking of the component shall include the following:

Ex II 2 G Ex db IIC Gb

Certification Manager

Jan-Erik Storgaard

This is to certify that the sample(s) of the Component described herein ("Certified Component") has been investigated and found in compliance with the Standard(s) indicated on this Certificate, in accordance with the ATEX Product Certification Program Requirements. This certificate and test results obtained apply only to the component sample(s) submitted by the Manufacturer. UL did not select the sample(s) or determine whether the sample(s) provided were representative of other manufactured component. UL has not established Follow-Up Service or other surveillance of the product. The Manufacturer is solely and fully responsible for conformity of all products to all applicable Standards, specifications, requirements or Directives. The test results may not be used, in whole or in part, in any other document without UL's prior written approval.

Date of issue: 2016-03-09

Re-issued: 2021-06-30

Notified Body

UL International Demko A/S, Ballerup 5A, 2750 Ballerup, Denmark
Tel. +45 44 85 65 65, info.dk@ul.com, www.ul.com

[13]

[14]

Schedule EU-TYPE EXAMINATION CERTIFICATE No. DEMKO 15 ATEX 1575U Rev. 3

[15] Description of Component:
The flameproof operators are utilized to complete a flameproof enclosure. The operators are threaded into a flameproof enclosure and utilize a shaft to attach an external operation device.

PUSH BUTTON CATALOG NUMBERS:

XHPB	PL
I	II

I	XHPB	PUSH BUTTON, STANDARD BUTTON, LONG
	XHPBS	PUSH BUTTON, STANDARD BUTTON, SHORT
	XHPBM	PUSH BUTTON, MUSHROOM HEAD BUTTON, LONG
	XHPBMS	PUSH BUTTON, MUSHROOM HEAD BUTTON, SHORT
II	PL	LOCKOUT DEVICE

PUSH PULL CATALOG NUMBERS

XHPPM	PUSH, PULL, LONG, STANDARD OPERATION
XHPPMS	PUSH, PULL, SHORT, STANDARD OPERATION
XHPPM-TTR	PUSH, PULL, LONG, TWIST TO RELEASE OPERATIONS
XHPPMS-TTR	PUSH, PULL, SHORT, TWIST TO RELEASE OPERATIONS

RECESSED RESET BUTTON CATALOG NUMBERS

XRBR	A
I	II

I	XRBR	RECESSED RESET BUTTON
II	A	ADDITIONAL LETTERS OR NUMBERS

KEYED SELECTOR SWITCH CATALOG NUMBERS

XHKSS	KEYED SELECTOR SWITCH, LONG, STANDARD ACTIVATION, 2 OR 3 POSITION (NO SPRING RETURN)
XHKSC	KEYED SELECTOR SWITCH, LONG, SPRING RETURN ACTIVATION TO CENTER FROM LEFT AND RIGHT, 3 POSITION
XHKSL	KEYED SELECTOR SWITCH, LONG, SPRING RETURN ACTIVATION TO CENTER FROM LEFT, 3 POSITION
XHKSL2	KEYED SELECTOR SWITCH, LONG, SPRING RETURN ACTIVATION TO CENTER FROM LEFT, 2 POSITION
XHSR	KEYED SELECTOR SWITCH, LONG, SPRING RETURN ACTIVATION TO CENTER FROM RIGHT, 3 POSITION
XHKSR2	KEYED SELECTOR SWITCH, LONG, SPRING RETURN ACTIVATION TO CENTER FROM RIGHT, 2 POSITION
XHKSSS	KEYED SELECTOR SWITCH, SHORT, STANDARD ACTIVATION, 2 OR 3 POSITION (NO SPRING RETURN)
XHKSSC	KEYED SELECTOR SWITCH, SHORT, SPRING RETURN ACTIVATION TO CENTER FROM LEFT AND RIGHT, 3 POSITION
XHKSSL	KEYED SELECTOR SWITCH, SHORT, SPRING RETURN ACTIVATION TO CENTER FROM LEFT, 3 POSITION
XHKSSL2	KEYED SELECTOR SWITCH, SHORT, SPRING RETURN ACTIVATION TO CENTER FROM LEFT, 2 POSITION
XHKSSR	KEYED SELECTOR SWITCH, SHORT, SPRING RETURN ACTIVATION TO CENTER FROM RIGHT, 3 POSITION
XHKSSR2	KEYED SELECTOR SWITCH, SHORT, SPRING RETURN ACTIVATION TO CENTER FROM RIGHT, 2 POSITION



[13]

[14]

Schedule

EU-TYPE EXAMINATION CERTIFICATE No.

DEMKO 15 ATEX 1575U Rev. 3

SELECTOR SWITCH CATALOG NUMBERS

XHSR	PL
I	II

I	XHSS	SELECTOR SWITCH, LONG, STANDARD ACTIVATION, 2 OR 3 POSITION (NO SPRING RETURN)
	XHSC	SELECTOR SWITCH, LONG, SPRING RETURN ACTIVATION TO CENTER FROM LEFT AND RIGHT, 3 POSITION
	XHSL	SELECTOR SWITCH, LONG, SPRING RETURN ACTIVATION TO CENTER FROM LEFT, 3 POSITION
	XHSL2	SELECTOR SWITCH, LONG, SPRING RETURN ACTIVATION TO CENTER FROM LEFT, 2 POSITION
	XHSR	SELECTOR SWITCH, LONG, SPRING RETURN ACTIVATION TO CENTER FROM RIGHT, 3 POSITION
	XHSR2	SELECTOR SWITCH, LONG, SPRING RETURN ACTIVATION TO CENTER FROM RIGHT, 2 POSITION
	XHSSS	SELECTOR SWITCH, SHORT, STANDARD ACTIVATION, 2 OR 3 POSITION (NO SPRING RETURN)
	XHSSC	SELECTOR SWITCH, SHORT, SPRING RETURN ACTIVATION TO CENTER FROM LEFT AND RIGHT, 3 POSITION
	XHSSL	SELECTOR SWITCH, SHORT, SPRING RETURN ACTIVATION TO CENTER FROM LEFT, 3 POSITION
	XHSSL2	SELECTOR SWITCH, SHORT, SPRING RETURN ACTIVATION TO CENTER FROM LEFT, 2 POSITION
	XHSSR	SELECTOR SWITCH, SHORT, SPRING RETURN ACTIVATION TO CENTER FROM RIGHT, 3 POSITION
	XHSSR2	SELECTOR SWITCH, SHORT, SPRING RETURN ACTIVATION TO CENTER FROM RIGHT, 2 POSITION
II	PL	LOCKOUT DEVICE

MULTI-POSITION SWITCH CATALOG NUMBERS

XSS	-	4P
I	II	III

I	XSSL	SELECTOR SWITCH, LONG
	XSSSS	SELECTOR SWITCH, SHORT
II	DASH	
III	ADDITIONAL LETTERS OR NUMBERS	

POTENTIOMETER CATALOG NUMBERS

XPO	POTENTIOMETER, LONG, STANDARD DIAL
XPOS	POTENTIOMETER, SHORT, STANDARD DIAL
XPOC	POTENTIOMETER, LONG, COUNTER DIAL
XPOCS	POTENTIOMETER, SHORT, COUNTER DIAL
XPOL	POTENTIOMETER, LONG, LARGE DIAL
XPOLS	POTENTIOMETER, SHORT, LARGE DIAL

RESET BUTTON CATALOG NUMBERS

XRB	A
I	II

I	XRB	RESET BUTTON, SHORT
	XRBL	RESET BUTTON, LONG
II	ADDITIONAL LETTERS AND NUMBERS	

DUAL PUSH BUTTON CATALOG NUMBERS

XHDPB	L
I	II

I	XHDPB	DUAL PUSH BUTTON, LONG, MOMENTARY CONTACT
	XHDPBS	DUAL PUSH BUTTON, SHORT, MOMENTARY CONTACT
	XHDMC	DUAL PUSH BUTTON, LONG, MAINTAINED CONTACT
	XHDMCS	DUAL PUSH BUTTON, SHORT, MAINTAINED
II	L	LOCKOUT DEVICE



[13]

[14]

Schedule
EU-TYPE EXAMINATION CERTIFICATE No.
DEMKO 15 ATEX 1575U Rev. 3

COUPLING SHAFT CATALOG NUMBERS

XCS	2
I	II

I	XCS	COUPLING SHAFT
II	2	1/4 DIAMETER
	3	5/16 DIAMETER
	5	1/2 DIAMETER

INTERMEDIATE RESET BUTTON CATALOG NUMBERS

XIRB	INTERMEDIATE RESET BUTTON, LONG
XIRBS	INTERMEDIATE RESET BUTTON, SHORT

MINIATURE PUSH BUTTON CATALOG NUMBERS

XMOB	-	1
I	II	III

I	XMOB	MINIATURE PUSH BUTTON, LONG
	XMOBS	MINIATURE PUSH BUTTON, SHORT
II	DASH	
III	ADDITIONAL LETTERS AND NUMBERS	

MINIATURE RESET BUTTON CATALOG NUMBERS

XMORB	MINIATURE RESET BUTTON, LONG
XMORBS	MINIATURE RESET BUTTON, SHORT

MINIATURE SELECTOR SWITCH CATALOG NUMBERS

XMOS	-1
I	II

I	XMOS	MINIATURE SELECTOR SWITCH, LONG
	XMOSS	MINIATURE SELECTOR SWITCH, SHORT
II	ADDITIONAL LETTERS OR NUMBERS	

MINIATURE PILOT LIGHT CATALOG NUMBERS

XMOL	A	120V
I	II	III

I	XMOL	MINIATURE PILOT LIGHT
II	A	AMBER
	B	BLUE
	C	CLEAR
	G	GREEN
	R	RED
	W	WHITE
III	120V	120 VOLTS AC OR DC
	24V	24 VOLTS AC OR DC
	12V	12 VOLTS AC OR DC



[13]

[14]

Schedule
EU-TYPE EXAMINATION CERTIFICATE No.
DEMKO 15 ATEX 1575U Rev. 3

PILOT LIGHT CATALOG NUMBERS

XLX	R	120	-	G
I	II	III	IV	V

I	XLX	PILOT LIGHT, LONG
	XLXS	PILOT LIGHT SHORT
II	A	AMBER
	B	BLUE
	C	CLEAR
	G	GREEN
	R	RED
	W	WHITE
III	120	VOLTAGE (12-120, 240)
IV	-	DASH
V	G	GUARDED CAP

LIGHTED PUSH BUTTON CATALOG NUMBERS

XLPX	A	X	12
I	II	III	IV

I	XLP	LIGHTED PUSH BUTTON, LONG
	XLPS	LIGHTED PUSH BUTTON, SHORT
II	A	AMBER
	B	BLUE
	C	CLEAR
	G	GREEN
	R	RED
	W	WHITE
III	X	
IV	12	VOLTAGE (12-120, 240)

LARGE BREAKER HANDLE CATALOG NUMBERS

XCBH2	-	1
I	II	III

I	XCBH2	BREAKER HANDLE
II	-	DASH
III	ADDITIONAL LETTER AND NUMBERS	

SMALL HANDLE CATALOG NUMBERS

X2PB	1	-H	GR1
I	II	III	IV

I	X2PB	SMALL HANDLE, PANELBOARD
II	ADDITIONAL LETTERS AND NUMBERS	
III	-H	
IV	ADDITIONAL LETTERS AND NUMBERS	



[13]

[14]

Schedule
EU-TYPE EXAMINATION CERTIFICATE No.
DEMKO 15 ATEX 1575U Rev. 3

XCBH	21
I	II

I	XCBH	SMALL HANDLE, BREAKER
II	ADDITIONAL LETTERS AND NUMBERS	

XRSO1	1
I	II

I	XRSO1	SMALL HANDLE, ROTARY STYLE
II	ADDITIONAL LETTERS AND NUMBERS	

OPERATORS HANDLE CATALOG NUMBERS

XBO2	-	6
I	II	III

I	XBO2	OPERATOR HANDLE, LONG
	XBOS2	OPERATOR HANDLE, SHORT
II	-	DASH
III	ADDITIONAL LETTERS AND NUMBERS	

Temperature range
The ambient temperature range is -50 °C to +100 °C.

Routine tests
Routine tests according to EN 60079-1 cl. 16 are not required, as the enclosures have been successfully tested at four times the reference pressure.

[16]

Descriptive Documents
The scheduled documents are listed in the report no. provided under item no. [8] on page 1 of this EU-Type Examination Certificate.

[17]

Schedule of limitations:

- Repairs of flameproof joints are not permitted. If a flameproof joint is damaged please contact Adalet.
- WARNING: WIPE WITH DAMP CLOTH TO REDUCE THE POTENTIAL FOR ELECTRO-STATIC DISCHARGE.

[18]

Essential Health and Safety Requirements
The Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9.

Additional information
The operators have in addition passed the tests for Ingress Protection to IP 66 in accordance with EN60529:1991+A1:2000+A2:2013.

The manufacturer shall inform the notified body concerning all modifications to the technical documentation as described in Annex III to Directive 2014/34/EU of the European Parliament and the Council of 26 February 2014.

