

# Certificate of Compliance

Certificate:

1113894 (LR 27991-44)

Master Contract: 150014

**Project:** 

1421204

Date Issued: May 12, 2003

Issued to:

ADALET-PLM 4801 W, 150 th St.

Cleveland OH 44135

**USA** 

Attention:

Mr. Timothy Snelly

The products listed below are eligible to bear the CSA Mark shown



Issued by:

D/Somma C.E.T.

Authorized by: Nick Alfano

Operations Manager

#### **PRODUCTS**

CLASS 4418 03 - CONDUIT FITTINGS - Fittings For Metal Conduit - For Hazardous Locations

Class I, Groups C and D:

Conduit fitting for draining and venting Cat. No. XFA-2, ½ in trade size.

Class I, Groups B, C and D:

Conduit fitting for draining and venting Cat. No. XFAX-2, ½ in trade size.

#### APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 0.5-1979 - Threaded Conduit Entries

CSA Standard C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations

#### **MARKINGS**

The head of each fitting is metal stamped with: Submitter's Name, Cat. No. Designation, Hazardous Location Designation and the CSA Monogram



## Supplement to Certificate of Compliance

Certificate: 11138

1113894 (LR27991-44)

Master Contract: 150014

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

### **Product Certification History**

Project	Date	Description
1421204 1150567	May 12, 2003 Feb. 7, 2001	Addition of alternate Manufacturer of sintered element.  Update to add flame arrestor fitting model XFAX-2 for Class I, Groups B, C and D.
1113 <b>89</b> 4 -44	July 31, 2000 Feb. 7, 1990	Update to add new model XFAX-2 and to change drawings.  Original Certification



## Descriptive and Test Report

MASTER CONTRACT: 150014

**REPORT:** 1113894 (LR 27991-44)

**PROJECT:** 1421204

Edition 1:

February 7, 1990; Application No LR 27991-44 - Toronto

Issued by D. Somma, CET

**Edition 2:** 

July 31, 2000; Project 1113894 - Toronto

Issued by D. Somma, CET

Report Pages Reissued

**Edition 3:** 

February 7, 2001; Project 1150567 - Toronto

Issued by Ezio Migliozi; Reviewed by D. Somma, CET

Report Pages Reissued

Attachments Added: Appendix I (Kept in Engineering File Only)

**Edition 4:** 

May 12, 2003; Project 1421204 - Toronto

Issued by D. Somma, C.E.T.

Report Pages Reissued

Drawings Updated: 6124, 20338

Replaced Drawing: 20336 replaces 6126

Contents:

Certificate of Compliance - Page 1

Supplement to Certificate of Compliance - Page 1

Description and Tests - Pages 1 to 5 Fig. 1 – UL report File E 10493

Descriptive Document Drawings (Drawing Nos.: 6124, 20336, 7887, 20338)

Attachments - Appendix I (Kept in Engineering File Only)

#### **PRODUCTS**

CLASS 4418 03 - CONDUIT FITTINGS - Fittings For Metal Conduit - For Hazardous Locations

Class I, Groups C and D:

Conduit fitting for draining and venting Cat. No. XFA-2, ½ in trade size.

Class I, Groups B, C and D:

Conduit fitting for draining and venting Cat. No. XFAX-2, ½ in trade size

The test report shall not be reproduced, except in full, without the approval of CSA International.

**REPORT:** 1113894 **PROJECT:** 1421204

Page No: 2 Date Issued: May 12, 2003

#### **APPLICABLE REQUIREMENTS**

CSA Standard C22.2 No. 0.5-1979 - Threaded Conduit Entries - Explosion-Proof Enclosures for Use in Class I Hazardous Locations

#### **MARKINGS**

The head of each fitting is metal stamped with: Submitter's Name, Cat. No. Designation, Hazardous Location Designation and the CSA Monogram.

#### **ALTERATIONS**

Markings as stated above.

#### **FACTORY TESTS**

None required.

**REPORT:** 1113894 **PROJECT:** 1421204

Page No: 3
Date Issued: May 12, 2003

#### **DESCRIPTION**

#### Part A - Model XFA-2

General: The submitter provided a copy in a form of UL report file E10493, issued September 19, 1988 describing the subject fitting. Attached as Fig 1. The submitter also provided updated drawings of the construction of the subject fitting not covered under the mentioned UL file.

<u>Construction</u>: Updated drawings Nos 20336 and 6124 illustrate the present construction, supercedes the same Drawing Nos attached in the UL report.

#### Part B- Model XFAX-2

General: The construction is the same as the model XFA-2, except the length of the flame arrestor element was increased from .375" to .500" and the snap ring location in the body of the fitting was moved to accommodate the longer element.

Descriptive Documents Flame Arrestors Cat. Nos. XFA-2 & XFAX-2:									
Subject	<b>Drawing</b>	Rev.	<u>Date</u>						
SS Sintered Element	6124	G	02/25/03						
XFA-2 Flame Arrestor Assembly	20336	N	02/28/03						
Bulkhead fitting body for flame arrester	7887	В	04/18/00						
XFAX-2 Bulkhead fitting body for flame arrester	20338	D	02/28/03						

**REPORT:** 1113894 **PROJECT:** 1421204 Page No: 4
Date Issued: May 12, 2003

#### **TEST REPORT**

In addition to the test performed by UL a representative sample Cat No XFA-2 was subjected to the following test:

1. Explosion Flame Propagation Test: Std 30-M1986 Cl 6.5.4 (c)

Class I, Group C - 37 +/- 0.5 percent hydrogen mixed with air five (5) trials were performed: Max Expl. pressure recorded 95 psi.

Results: There was no external mixture ignition. Satisfactory.

In view of the above, no further tests were deemed necessary.

<u>Project 1113894:</u> Additional test was not requested due to the flame path was increased creating a margin of safety for preventing the transmission of flame.

<u>Project 1150567:</u> Tests were performed by CSA Laboratory and detail Test Data is attached under Appendix I, (Kept in Eng. File only).

Summary of the Tests are as follows:

A sample of model XFAX2 flame arrestor (1/2 in Trade Size) was subjected to the following Tests:

1. Overpressure Test: CSA C22.2 No.30, Clause 6.11

A 8000 kPa (1160 psi) pressure was applied for 1 min.

Result: Satisfactory.

2. Explosion Flame Propagation Test for Flame Arrestors: CSA C22.2 No. 30, Clause 6.5.4

The sample was installed in the outer wall of the test enclosure and submitted to 5 shots of a mixture 40.0% Hydrogen and 20% Oxygen.

Result: No propagation. Satisfactory.

No further tests were considered necessary

**REPORT:** 1113894 **PROJECT:** 1421204

Project No. 1421204: This Project covers the addition of alternate manufacturer of Sintered Element that is incorporated into the flame arrestor fittings. The sintered element has the same characteristics as the one that is currently used. The manufacturer of the sintered element tested the sintered element according to ISO Standard 4003:1977 ( Determination of Bubble Test Pore Size); ISO Standard 4022:1973(Fluid Permeability) and ISO Standard 2738:1987( Density and open Porosity). Records are kept in the correspondence file.

Page No: 5

Date Issued: May 12, 2003

One sample of Cat. No. XFA-2 (Cl. I, Gr. C & D) was subjected to a Hydrostatic Overpressure of 600 psig/min


One sample of Cat. No. XFAX-2 (Cl. I, Gr. B, C & D) was subjected to a Hydrostatic Overpressure of 1160 psig/min.

In View of the above the only test deemed necessary was as follows:

**Results**: Satisfactory

* 75 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5	AC PE							[1]							T	]					
TOR CORNER NUM 1/8"	DO NOT SCALE DRAWING SSS OFFICENCY NESCONS ARE IN INCHES. POLIERANCES ON DIALENSIONS OFFICENCY NESCONS SPECIFIED.	6124-1	6124	PART#		ar:		4.		C) DETE	B) DENS	A) EQUIV	DETERMI	STANDAR	3. SUPPLIED	_	(1.6mm): 2. VENDOR:	.063 x .	MISSING	NOTEV:	:
	MACHINE TOLERANCES ON DIMEN- SIONS NOT OTHERWISE SPECIFICS:  ("= 125"	.500(12.7MM)	.375(9.5MM)	"A"	PART	ME	25.5	SE MOTT STAN	FLUID PERMEABILITY IN ACCORDA ISO STANDARD 2738 AND 4022.	DETERMINATION OF	DENSITY OF SINTERED	BY METHOD SPECIF	DETERMINATION OF:	D EN 50018			×	.032 × .032 0	MISSING MATERIAL MAY NOT FYCEED	at .	
NOTE TO PRESIDE RESONG THIS DIREGUE.  ANDEET-PLU CLAUS PROPRETIEN ROTHS IN THE MITTEN  DESCENT PERSON THIS DIREGUE IS ESSED IN CONPRODUCE PRIX DIRECTURE AND THE MITTEN PRODUCED IN USED TO MAINFACTURE AND THIS SHOWN HERETH WINDLY  DREET WINTEN PERMISSION FROM ANALY-PLU TO THE USES.	ADALH TO SS SINTERED A SCOTI FETZER COMPANY Enclosure Systems - Cable Accessories	15005377500-100	1043982-01-999	MOTT PART #	T IDENTIFICATIO	Master Contrato 150014	ROJECT NO. 1421204	PURCHASE MOTT STANDARD PART WITH .377±.005.	FLUID PERMEABILITY IN ACCORDANCE WITH ISO STANDARD 2738 AND 4022.	DETERMINATION OF OPEN POROSITY AND/OR	ED ELEMENT IN	BUBBLE TEST PORE SIZE  ) SPECIFIED IN ISO STANDARD 4003.			WITH EACH ORDER: WITH EACH ORDER:	VENDOR: CHAND METALLURGICAL G	8mm)x(.8mm)  MOTT METAL CO. (CONN.)	× .032 ON ANY EXTERNAL SUFACE	NOT EXCEED	9	
NATURAL DNG NO 6 1 2 4	ERED ELEMENT BNG APPROVAL 3/3/3 PLOT SCALE	)-100	CMS375375-100	CHAND PART# G	ON TABLE					ø.375 .386 <b>SE</b> .	5 [ E N	9.520 9.650 OTE	-						ADDED ALTERNATE VENDOR	E UPDATED TO LATEST ENG. STD., ADDED PART TABLE MA	REV REVISION B
10F1 G	02/23/00 4=1									V	<u>1</u> ,			^ =					$\vdash$	MAD 5805 02/23/00 AAM 6214 01/04/01	BY ECN DATE

\* + 12 + 2 + 2 - 7



DO NOT SCALE DIAWING
ASS OTHERWISE SPECIFIED
BESONS ARE IN INCHES.
"TO LEGALICES ON DIAGOS
OTHERWISE SPECIFIED:
1/8 STOCK
1/8

TOTALERANCES ON DIMEN-

FETZER COMPANY
Cable Accessories

XFA-2 FLAME ARRESTOR ASSEMBLY

TANOMER DICE

KM 3/3/0

PLOT SCALE

/11/96

1

NAME OF THE

XFA-2

20336

10F1

