

EU-TYPE EXAMINATION CERTIFICATE



Component intended for use on/in Equipment or Protective System Intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU

EU-Type Examination Certificate Number: **DEMKO 03 ATEX 0303070U Rev. 2**

Component: **Type XJ Series Flameproof Enclosure**

Manufacturer: **Adalet/Scott Fetzer Co.**

Address: **4801 W. 150th Street, Cleveland, OH 44135 USA**

This product and any acceptable variation thereto are specified in the schedule to this certificate and the documents therein referred to.

UL International Demko A/S, notified body number 0539 in accordance with Article 17 of the Council Directive 2014/34/EU of the European Parliament and the Council, dated 26 February 2014, certifies that this component has been found to comply with the Essential Health and Safety Requirements relating to design and construction of components intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential report no. **US/UL/ExTR13.0039/02.**

Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN IEC 60079-0:2018



EN 60079-1:2014

EN 60079-31:2014

The sign "U" is placed after the certificate number. It indicates that this certificate must not be mistaken for a certificate intended for an equipment or protective system. This partial certification may be used as a basis for certification of an equipment or protective system.

This EU-Type Examination Certificate relates only to the design and construction of the specified component. Further requirements of the Directive apply to the manufacturing process and supply of this component. These are not covered by this certificate.

The marking of the component shall include the following:

 II 2 G **Ex db IIB+H₂ Gb**
 II 2 D **Ex tb IIIC Db**

Certification Manager
Thomas Wilson

This is to certify that the sample(s) of the Component described herein ("Certified Component") has been investigated and found in compliance with the Standard(s) indicated on this Certificate, in accordance with the ATEX Product Certification Program Requirements. This certificate and test results obtained apply only to the component sample(s) submitted by the Manufacturer. UL did not select the sample(s) or determine whether the sample(s) provided were representative of other manufactured component. UL has not established Follow-Up Service or other surveillance of the product. The Manufacturer is solely and fully responsible for conformity of all products to all applicable Standards, specifications, requirements or Directives. The test results may not be used, in whole or in part, in any other document without UL's prior written approval.

Date of issue: 2013-06-07

Re-issued: 2023-02-28

Notified Body

UL International Demko A/S, Ballerup 5A, 2750 Ballerup, Denmark
Tel. +45 44 85 65 65, info.dk@ul.com, www.ul.com

Accredited by DANAK under registration number 7011 to certification of products.



[13]

Schedule

[14]

EU-TYPE EXAMINATION CERTIFICATE No. DEMKO 03 ATEX 0303070U Rev. 2

[15]

Description of Component:

The XJ series of cast enclosures constructed of aluminium or 316 stainless steel for use with threaded covers, containing specifications for threaded conduit entries and other threaded entries for various sized auxiliary operators. The covers are flat and may also include a glass viewing window that is cemented and mechanically retained in place.

Type variants covered by the certification:

<u>XJ</u> I	<u>D</u> II	<u>HX</u> III	<u>6</u> IV	<u>N4</u> V
----------------	----------------	------------------	----------------	----------------

I – Enclosure Material and type
XJ- Series Designation

II – Enclosure Cover
D, DF, DA, HA, HB, HC, K, KA, L, M, MA, MC, N6, N12, S, T, WH, WT, X, DFGC, DGC, HAGC, HBGC, HCGC, KGC, KAGC, LGC, MGC, MAGC, MCGC, NGC6, NGC12, TFGC, TGC, WHGC, WTGC, XGC

III - Marking Designation
HX- (Class I, Groups B, C and D; Class I, Zone 1, IIB + H2)

IV – Enclosure Size
Blank- Standard
6 – 6 inch (only available on XJN and XJNGC)
12 – 12 inch (only available on XJN and XJNGC)

V - Environmental Designation
N4- Type 4 Rating
N4X – Type 4X Rating

Temperature range

The ambient temperature range is -50°C to +100 °C for use with a silicone o-ring and a solid cover.

The ambient temperature range is -34°C to +100°C for use with a Nitrile Buna N o-ring and either Adaseal or Adaseal II.

Routine tests

Routine tests according to Clause 16 EN60079-1 are required on the XJNGCHX6 and XJNGCHX12 enclosures using a pressure of 18.8 bar (273 PSI).

[16]

Descriptive Documents

The scheduled documents are listed in the report no. provided under item no. [8] on page 1 of this EU-Type Examination Certificate.

[17]

Schedule of limitations:

- For enclosure outline dimensions, conduit/cable layout, and conduit/cable drilling and tapping instructions, refer to supplied datasheet.
- The certification applies to equipment without cable glands. Only cable glands certified for protection types 'db', 'tb', and have an IP66 rating may be used.
- To minimize the risk of electrostatic charge, provisions shall be made for adequate grounding and equipment shall be installed in such a manner so that accidental discharge shall not occur.
- Refer to supplied enclosure drawing for conduit/cable entry locations and sizes. Additional copies may be obtained from the factory. Include the enclosure serial number with any request.
- Oil-filled circuit breakers and contactors shall not be used.
- Rotating machines, or other devices which create turbulence, shall not be incorporated.
- The Hazardous Location Solutions reducers shall not be used for the direct inter-connection of enclosures.
- Only one Hazardous Location Solutions reducer shall be used with any single cable entry on the associated equipment.
- All conduit sealing fittings must be certified as flameproof 'db', dust ignition protection 'tb', and have a minimum IP66 rating equal to the marking on the enclosure.
- All unused device openings must be fitted with a certified close-up plug with protection types 'db', 'tb', and have an IP66 rating.
- The content of the Ex component enclosure equipment may be placed in any arrangement provided that an area of at least 40% of each cross-sectional area remains free to permit unimpeded gas flow and therefore, unrestricted development of an explosion.
- Enclosures shall be installed to a flat rigid surface using the mounting means provided.
- The end user shall provide earthing/bonding means as necessary.

[18]

Essential Health and Safety Requirements

The Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9.

Accredited by DANAK under registration number 7011 to certification of products.



[13]


[14]

Schedule
EU-TYPE EXAMINATION CERTIFICATE No.
DEMKO 03 ATEX 0303070U Rev. 2

Additional information

The XJ series of enclosures has in addition passed the tests for Ingress Protection to IP 66 in accordance with EN60529:1991+A1:2000+A2:2013.



The trademark  will be used as the company identifier on the marking label.

The manufacturer shall inform the notified body concerning all modifications to the technical documentation as described in Annex III to Directive 2014/34/EU of the European Parliament and the Council of 26 February 2014.

Accredited by DANAK under registration number 7011 to certification of products.

