



XCE 0613 COVER

- NOTES:
1. MINIMUM SPACING FROM CENTER OF OPERATOR TO NEAREST FLAT IS 1 1/8".
 2. MINIMUM SPACING BETWEEN 1 AND 2 OPERATOR CENTERS IS 2 1/4" FOR THIS ENCLOSURE.
 3. MAXIMUM NUMBER OF OPERATORS IS 24.
 4. DIMENSION FROM CENTER LINES OF COVER FOR OPERATORS.
 5. DIMENSION FROM CENTER LINE AND BACK OF MFG. LUG FOR CONDUIT.
 6. FOR MFG. ENCLOSURE USE 3/8" BOLT.

		MODIFIED XCE/XUF 061305 ENCLOSURE FOR	
DATE: 6-12-01 DRAWN BY: DDH CHECKED BY: TUMBLAST XCE/XUF 061305	DATE: 6-12-01 DRAWN BY: DDH CHECKED BY: TUMBLAST XCE/XUF 061305	DATE: 6-12-01 DRAWN BY: DDH CHECKED BY: TUMBLAST XCE/XUF 061305	DATE: 6-12-01 DRAWN BY: DDH CHECKED BY: TUMBLAST XCE/XUF 061305