



XCE 0808 COVER

- NOTES:
1. MINIMUM SPACING FROM CENTER OF OPERATOR TO NEAREST FLAT IS 1 1/4" ALLOWABLE IN XCE ONLY.
 2. MINIMUM SPACING BETWEEN #1-14 NPSM OPERATOR CENTERS IS 2 1/2" FOR THIS ENCLOSURE.
 3. MAXIMUM NUMBER OF OPERATORS IS 4.
 4. DIMENSION FROM CENTER LINE OF COVER FOR OPERATORS.
 5. DIMENSION FROM CENTER LINE AND BACK OF MFG. LUG FOR CONDUIT.
 6. FOR MFG. ENCLOSURE USE 3/8 BOLT.

		MODIFIED XCE/XUF 080808 ENCLOSURE FOR	
DATE: 6-12-01 DRAWN BY: DDH CHECKED BY: 1-2 DESIGNED BY: D	TUBELAST XCE/XUF 080808	10F1	10F1