



EXISTING GRD. SCREW

XCE 0810 COVER

- COVER DRILLING ALLOWABLE IN XCE ONLY
- NOTES:
1. MINIMUM SPACING FROM CENTER OF OPERATOR TO NEAREST FLAT IS 1 1/8".
  2. MINIMUM SPACING BETWEEN 1-14 NPSM OPERATOR CENTERS IS 2 1/2" FOR THIS ENCLOSURE.
  3. MAXIMUM NUMBER OF OPERATORS IS 6.
  4. DIMENSION FROM CENTER LINES OF COVER FOR OPERATORS.
  5. DIMENSION FROM CENTER LINE AND BACK OF MTG. LUG FOR CONDUIT.
  6. FOR MTG. ENCLOSURE USE 3/8 BOLT.

|  |  |   |  |  |  |
|--|--|---|--|--|--|
| <p>NO HOT SCALE BRANDING</p> <p>TUMBLAST OPERATING SPECIFICATIONS</p> <p>CAT NO. XCE/XJF 081008</p> <p>FILET OR CORNER RADIUS 1/8"</p> <p>FILET RADIUS 1/16"</p> <p>ANGLES ± 1°</p> <p>± .005</p> <p>FILET RADIUS .03" ± .015" R. or .45"</p> <p>ANGLES ± 0° .50"</p> <p>QUALIFYING FROM TUMBLAST LOGS</p> <p>REF. E-21-2.6</p> <p>WHSE E-24-1.0</p> |  | <p><b>ADALTETT</b></p> <p>A SCOTT FETTER COMPANY</p> <p>Manufacturers of Quality Enclosures</p> <p>NOTICE TO PERSONS RECEIVING THIS DRAWING: INCLOSED VERSION OF THE DRAWING IS ISSUED IN CONNECTION WITH THE TUMBLAST OPERATOR CENTER AND SHALL BE USED ONLY FOR THE PURPOSES SPECIFIED HEREIN. ANY OTHER REPRODUCTION OR USE OF THIS DRAWING WITHOUT THE WRITTEN PERMISSION FROM ADALTETT IS TO BE CONSIDERED UNLAWFUL.</p> |  | <p>MODIFIED XCE/XJF 081008 ENCLOSURE FOR</p> <p>DESIGNED BY: DDH</p> <p>DATE: 6-12-01</p> <p>SCALE: 1=4</p> <p>DWG APPROVAL: C</p> <p>DWG NO. 10F1</p> |  |
|--|--|---|--|--|--|