



OPTIONAL XHB-2 HINGE

EXISTING GRD. SCREW

OPTIONAL MTC. PAN

XCE 0812 COVER

- NOTES:
1. MINIMUM SPACING FROM CENTER OF OPERATOR TO NEAREST FLAT IS 1 1/8".
  2. MINIMUM SPACING BETWEEN 1-14 WPSM OPERATOR CENTERS IS 2 1/2" FOR THIS ENCLOSURE.
  3. MAXIMUM NUMBER OF OPERATORS IS 8. COVER FOR OPERATORS.
  4. DIMENSION FROM CENTER LINE AND BACK OF MTC. LUG FOR CONDUIT.
  5. DIMENSION FROM CENTER LINE AND BACK OF MTC. LUG FOR CONDUIT.
  6. FOR MTC. ENCLOSURE USE 3/8" BOLT.

		MODIFIED XCE/XUF 081204 ENCLOSURE FOR	
XCE/XUF 081204 TUMBLAST	DDH 1-25 D	6-13-01 10F1	10F1