


XCE 1616 COVER



- NOTES:
1. MINIMUM SPACING FROM CENTER OF OPERATOR TO NEAREST FLAT IS 1 1/4" ALLOWABLE IN XCE ONLY.
 2. MAXIMUM SPACING BETWEEN #1-14 NPSM OPERATOR CENTERS IS 3/4" FOR THIS ENCLOSURE.
 3. MAXIMUM NUMBER OF OPERATORS IS 16.
 4. DIMENSION FROM CENTER LINE OF COVER FOR OPERATORS.
 5. DIMENSION FROM CENTER LINE AND BACK OF MFG. LUG FOR CONDUIT.
 6. FOR MFG. ENCLOSURE USE # BOLT.

		MODIFIED XCE/XUF 161606 ENCLOSURE FOR	
DATE: 11-14-01 BY: DDH CHECKED: 1-3-05 D	TUMBLAST XCE/XUF 161606	10F1	10F1