



- NOTES:
1. MINIMUM SPACING FROM CENTER OF OPERATOR TO NEAREST FLAT IS 1 1/8
  2. MINIMUM SPACING BETWEEN 1-14 NPSM OPERATOR CENTERS IS 3/4 FOR THIS ENCLOSURE.
  3. MAXIMUM NUMBER OF OPERATORS IS 36.
  4. DIMENSION FROM CENTER LINES OF COVER FOR OPERATORS.
  5. DIMENSION FROM CENTER LINE AND BACK OF MFG. LUG FOR CONDUIT.
  6. FOR MFG. ENCLOSURE USE 1/2 BOLT.
- COVER DRILLING ALLOWABLE IN XCE ONLY.

XCE 1634 COVER

		MODIFIED XCE/XAF 163406 ENCLOSURE FOR	
TUMBLAST XCE/XAF 163406	DDH	11-15-01	10F1