



- NOTES:
1. MINIMUM SPACING FROM CENTER OF OPERATOR TO NEAREST FLAT IS 14".
 2. MINIMUM SPACING BETWEEN 1/4" UPSH OPERATOR CENTERS IS 3/4" FOR THIS ENCLOSURE.
 3. MAXIMUM NUMBER OF OPERATORS IS 32.
 4. DIMENSION FROM CENTER LINE OF COVER FOR OPERATORS.
 5. DIMENSION FROM CENTER LINE AND BACK OF MFG. LUG FOR CONDUIT.
 6. FOR MFG. ENCLOSURE USE 1/2" BOLT.

XCE 1830 N4 COVER

		MODIFIED XCE0 183008 N4 ENCLOSURE FOR	
XCE 183008 N4 TUBELAST	DDH 11-16-01 1-4 D	10F1	10F1