



OPTIONAL XHF-3 HINGES

OPTIONAL MTC. PAN

EXISTING GRD. SCREW

XCE 1836 COVER

- COVER DRILLING ALLOWABLE IN XCE ONLY
1. MINIMUM SPACING FROM CENTER OF OPERATOR TO NEAREST FLAT IS 1 1/8"
  2. MINIMUM SPACING BETWEEN 1 1/8" SPACED OPERATOR CENTERS IS 3/4" FOR THIS ENCLOSURE.
  3. DIMENSION FROM CENTER LINES OF COVER FOR OPERATORS.
  4. DIMENSION FROM CENTER LINE AND BACK OF MTC LUG FOR CONDUIT.
  5. DIMENSION FROM CENTER LINE AND BACK OF MTC LUG FOR CONDUIT.
  6. FOR MTC ENCLOSURE USE 1/2" BOLT.

		MODIFIED XCE/XHF 183606 ENCLOSURE FOR	
TUNING FOR XCE/XHF 183606	DDH 11-16-01 1-5-25 D	10F1	10F1