



FM Approvals
1151 Boston-Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781 762 9375 www.fmglobal.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

XIHL-aXbc. Single Ended Instrument Housing - Domestic/European.

XP/II/1/BCD/T6; XP/II/1/IIIB+H₂; DIP/II,III/1/EFG/T6; Type 4X, IP66

a = Housing Cover: FC, FGC, DC, DGC, or EC.

b = Conduit Hub Size: 2 or none.

c = External Mounting Lugs: L or blank.

Non-Designated Options:

Front Pad Mounting Option

Front Pad Entrance Options

Internal Wall Entrance Options

Internal Wall Mounting Options

Internal Wall Terminal Strip Options

316 Stainless Steel Option

Painting Options

XDHL-aXbc. Double Ended Instrument Housing - Domestic/European.

XP/II/1/BCD/T6; XP/II/1/IIIB+H₂; DIP/II,III/1/EFG/T6; Type 4X, IP66

a = Instrument Side Cover: FC, FGC, DC, DGC.

b = Conduit Hub Size: 2 or none.

c = Power Side Cover: A, B or C.

Non-Designated Options:

Front Pad Mounting Option

Front Pad Entrance Options

Internal Wall Entrance Options

Internal Wall Mounting Options

Internal Wall Terminal Strip Options

316 Stainless Steel Option

Painting Options



Equipment Ratings:

Explosionproof for Class I, Division 1, Groups B, C and D; and Dust-Ignitionproof for Class II/III, Division 1, Groups E, F and G, hazardous (classified) locations, indoors and outdoors (Type 4X).

Explosionproof for Class I, Zone 1, Group IIB + H₂; hazardous (classified) locations, indoors and outdoors (IP66).

Approved for:

Adalet-PLM
4801 West 150th Street, Cleveland, OH 44135

[Faint, illegible text, likely bleed-through from the reverse side of the page]

[Faint, illegible text, likely bleed-through from the reverse side of the page]

[Faint, illegible text, likely bleed-through from the reverse side of the page]



This certifies that the equipment described has been found to comply with the following FM Approval Standards and other documents:

Class 3600	1998
Class 3615	1989
Class 3810	2005
ANSI/NEMA 250	1991
IEC 60529 +A1	2001


Original Project ID: 2Y4A1.AE

FM Approval Granted: August 1, 1995

Subsequent Revision Reports / Date FM Approval Amended

Report Number	Date	Report Number	Date
2B1A9.AE	May 30, 1997		
3011559	June 29, 2001		
3016299	June 10, 2003		
050420	<i>April 27, 2005</i>		

FM Global Technologies LLC



Roger L. Allard
Assistant Vice President
FM Approvals

April 27, 2005

Date